

**MUBENDE AREA****Report date:** 14<sup>th</sup> December -2015**Table:** Water quality for Selected zones in Mubende during the week starting 10<sup>th</sup> December 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				PSP	C.Valve	Dead End	Boma	Kaweri	
CODE		N2090	N2095	N2100	N2102	N2108	N2098	N2099	
pH	....	7.1	7.0	6.4	6.5	6.5	6.8	6.4	5.5 – 8.5
Turbidity	NTU	16	0	0	0	0	0	0	≤5.00
Colour	PtCo.	305	0	0	0	0	0	0	≤15
Iron	Mg/L	0.59	0	N/A	N/A	N/A	N/A	N/A	≤0.30
Residue Aluminium	Mg/L	NA	0.07	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	0.87	0.25	0.18	0.20	0.28	0.34	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	105	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required