

MUBENDE AREA**Report date:** 25th November-2015**Table:** Water quality for Selected zones in Mubende during the week starting 19th November 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				PSP	C.Valv e	Dead End	Boma	Kaweri	
CODE		N1918	N1923	N1928	N1930	N1934	N1926	N1927	
pH	7.6	7.08	6.7	6.75	6.53	6.74	6.78	5.5 – 8.5
Turbidity	NTU	20	0	0	0	0	0	0	≤5.00
Colour	PtCo.	443	0	0	0	0	0	0	≤15
Iron	Mg/l	0.78	0	NR	NR	NR	NR	NR	≤0.30
Residue Aluminium	Mg/l	N/A	0.07	NR	NR	NR	NR	NR	≤0.20
Free chlorine	Mg/L	N/A	1.18	0.21	0.33	0.17	0.3	0.39	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	96	0	0	0	0	0	0	0

N/A: Not applicable, N/R: Not Required