

MUBENDE AREA**Report date:** 30th November-2015**Table:** Water quality for Selected zones in Mubende during the week starting 26th November 2015

Parameter				Monitoring points					National Standard For potable water quality
	Unit	Raw water	Final water		Water in Supply				
				PSP	C.Valve	Dead End	Boma	Kaweri	
CODE		N1970	N1975	N1980	N1982	N1984	N1978	N1979	
pH	NA	7.3	7.2	6.8	6.7	6.6	6.7	6.9	5.5 – 8.5
Turbidity	NTU	22	0.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	461	0	0	0	0	0	0	≤15
Iron	Mg/l	0.88	0	ND	ND	ND	ND	ND	≤0.30
Residue Aluminium	Mg/l	N/A	0.07	ND	ND	ND	ND	ND	≤0.20
Free chlorine	Mg/L	N/A	1.09	0.31	0.33	0.22	0.34	0.26	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	84	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required