

MUBENDE AREA**Report date:** 8th December -2015**Table:** Water quality for Selected zones in Mubende during the week starting 3rd December 2015

Parameter	Unit	Raw water	Final water	Monitoring points					National Standard For potable water quality (Water in Supply)
				PSP	C.Valve	Dead End	Boma	Kaweri	
CODE		N2022	N2028	N2032	N2034	N2041	N2030	N2031	
pH	7.1	6.5	6.8	6.8	6.8	6.7	7.1	5.5 – 8.5
Turbidity	NTU	18	0	0	0	0	0	0	≤5.00
Colour	PtCo.	386	0	0	0	0	0	0	≤15
Iron	Mg/l	0.86	0	N/A	N/A	N/A	N/A	N/A	≤0.30
Residue Aluminium	Mg/l	N/A	0.13	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	1.05	0.28	0.26	0.15	0.31	0.34	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	105	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required