

MUBENDE AREA**Report date:** 22nd June 2015**Table:** Water quality for selected points in Mubende during the week of 15th June 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Petrocity	Lubanga Rd	Kasenyi	Bom a	Kaweri	
pH	...	6.53	6.27	6.69	6.69	6.64	6.53	7.20	5.5 – 8.5
Turbidity	NTU	15.2	2.92	0.53	0.33	0.89	0.89	0.34	≤5
Colour	PtCo.	372	12	2	3	2	10	4	≤15
Free chlorine	mg/L	N/A	0.6	0.2	0.2	0.3	0.1	0.2	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	340	0	0	0	0	0	0	0