

MUBENDE AREA**Report date:** 24th December -2015**Table:** Water quality for Selected zones in Mubende during the week starting 17th December 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				PSP	C.Valve	Dead End	Boma	Kaweri	
CODE		N2133	N2138	N2143	N2145	N2150	N2041	N2140	
pH	7.4	7.0	6.7	6.8	6.6	6.4	6.4	5.5 – 8.5
Turbidity	NTU	20.00	0.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	483	0	0	0	0	0	0	≤15
Iron	Mg/l	0.74	0	N/A	N/A	N/A	N/A	N/A	≤0.30
Residue Aluminium	Mg/l	NA	0.06	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	1.27	0.27	0.25	0.20	0.27	0.34	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	100	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required