

MUBENDE AREA**Report date:** 29th September -2015**Table:** Water quality for Selected points in Mubende during the week of 25th September 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				PSP	New Connect ion	Dead End	Control Valves	
Codes		N131	N132	N133	N134	N135	N136	
pH	8.1	7.0	7.0	6.9	7.0	7.0	5.5 – 8.5
Turbidity	NTU	28.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	331	0	0	0	0	0	≤15
Iron	Mg/l	N/D	N/D	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/R	N/D	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	1.14	0.22	0.30	0.22	0.32	0.21	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	ND	0	0	0	0	0	0

N/R-Not Required, N/D-Not Done