



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

MUTUKULA AREA

Report date: 30th June-2016

Table: Water quality for Selected points in Mutukula during the week of 24th June2016

Parameter				Monitoring points			National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply		
				Kabaho	Rwazi	Central	
CODE		M3098	M3099	M3100	M3101	M3102	
pH	6.0	6.7	6.7	6.7	6.5	5.5 – 8.5
Turbidity	NTU	0.54	0.67	0.93	0.98	0.58	≤5.00
Colour	PtCo.	0	0	4	7	3	≤15
Iron	Mg/l	0.013	0.014	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	NR	NR	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	NA	0.78	0.42	0.23	0.24	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	0	0	0	0	0	0