

NEBBI AREA**Report date:** 6th January-2016**Table:** Water quality for Selected zones in Nebbi during the week 31st December 2015

Parameter	Unit	Monitoring points						National Standard For potable water quality (Water in Supply)
		Raw water	Final water	Water in Supply				
				Red cross Nebbi	Juba village	Leosim Hotel	Royal Atlas Inn	
Codes		N1257	N1263	N1267	N1268	N1269	N1270	
pH	8.0	7.8	7.9	7.7	7.6	7.8	5.5 – 8.5
Turbidity	NTU	21.7	0.91	0.03	0.93	0.87	0.97	≤5.00
Colour	PtCo.	227	0	0	0	0	0	≤15
Iron	Mg/l	1.06	0.00	0.00	0.00	0.00	0.00	≤0.30
Residue Aluminium	Mg/l	N/A	0.00	0.00	0.00	0.00	0.00	≤0.20
Free chlorine	Mg/l	N/A	0.64	0.48	0.29	0.36	0.26	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	308	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required