

NEBBI AREA**Report date:** 13th January-2016**Table:** Water quality for Selected zones in Nebbi during the week of 7th January-2016.

Parameter	Unit	Raw water	Final water	Monitoring points					National Standard For potable water quality (Water in Supply)
				Water in Supply					
				Reservoir B	Thatha PSP	Nyacara Village	Omyer TC	Nebbi hospital	
CODE		N1325	N1331	N1334	N1335	N1336	N1337	N1338	
pH	8.1	8.0	8.0	7.9	7.6	8.0	7.5	5.5 – 8.5
Turbidity	NTU	21.90	1.16	0.04	0.32	0.33	0.42	0.13	≤5.00
Colour	PtCo.	198	6	0	0	0	9	3	≤15
Iron	Mg/L	1.180	0.000	0.000	0.000	0.000	0.000	0.000	≤0.300
Residue Aluminium	Mg/L	N/A	0.10	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	N/A	0.61	0.51	0.18	0.21	0.10	0.36	0.20 – 0.50
Faecal-Coliform	CFU/ 100 mL	646	0	0	0	0	0	0	0

N/A: Not applicable, N/R: Not Required