



NATIONAL WATER & SEWERAGE CORPORATION

WATER QUALITY MANAGEMENT DEPARTMENT

NEBBI AREA

Report date: 23rd June 2016

Table: Water quality for Selected zones in Nebbi during the week of 16th June, 2016.

Parameter	Unit	Monitoring Points					National Standards for potable water
		Water works		Water in Supply			
		Raw water	Final water	Kasuku PSP	Onduru PSP	Thartha PSP	
Codes		N519	N522	N523	N524	N525	
pH	...	8.1	7.6	7.7	7.9	7.7	5.5 – 8.5
Colour	PtCo.	270	3	0	2	4	≤15
Turbidity	NTU	27.9	0.96	0.93	1.01	1.20	≤5
Iron	mg/L	1.610	0.130	0.140	0.180	0.150	0.300
Free chlorine	mg/L	N/A	0.82	0.23	0.28	0.31	0.20 – 0.50
Aluminium residue	mg/L	N/A	0.11	N/R	N/R	N/R	0.200
Faecal Coliform	CFU/ 100 mL	126	0	0	0	0	0

N/A: Not applicable, N/R: Not Required