



NATIONAL WATER & SEWERAGE CORPORATION

WATER QUALITY MANAGEMENT DEPARTMENT

NEBBI AREA

Report date: 3rd November, 2016

Table: Water quality for Selected zones in Nebbi during the week of 27th October ,2016.

Parameter	Unit	Monitoring points							National Standards for potable water quality (Water in supply)
		Waterworks		Water in Supply					
		Raw water	Final water	Reservoir C	St. Thomas Educ. Centre	Arumukeng PSP	Lagi PSP	Royal Atlas Inn	
Codes		N790	N794	N795	N796	N797	N798	N799	
pH	8.2	7.8	7.7	7.6	7.5	7.7	7.7	6.5 – 8.5
Turbidity	NTU	60	1.08	0.98	1.06	1.00	0.95	1.09	≤5.00
Colour	PtCo.	627	0	0	0	0	0	0	≤15
Iron	mg/L	2.00	0.110	0.180	0.000	0.000	0.000	0.000	≤0.300
Free chlorine	mg/L	N/A	0.74	0.58	0.20	0.20	0.20	0.23	0.20 – 0.50
Faecal -Coliform	CFU/ 100 mL	750	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required