



**NATIONAL WATER & SEWERAGE CORPORATION  
WATER QUALITY MANAGEMENT DEPARTMENT**

**NEBBI AREA**

**Report date:** 6<sup>th</sup> April 2016

**Table:** Water quality for Selected zones in Nebbi during the week of 30<sup>th</sup> March, 2016.

Parameter	Unit	Monitoring points						National Standards for potable water (water in supply)
		Waterworks		Water in Supply				
		Raw water	Final water	Reservoir B	Chananyira PSP	Nebbi town S.S	Yetu station	
Codes		N2121	N2127	N2130	N2131	N2132	N2133	
pH	....	8.07	7.47	7.5	7.71	7.63	7.72	5.5 – 8.5
Turbidity	NTU	148	0.84	0.95	0.99	0.87	0.90	≤5.00
Colour	PtCo.	1314	0	0	0	0	0	≤15
Iron	mg/L	2.140	0.060	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	mg/L	N/A	0.12	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	NA	0.83	0.77	0.29	0.26	0.30	0.20 – 0.50
Faecal - Coliform	CFU/100 mL	928	0	0	0	0	0	0

N/A: Not applicable, N/R: Not Required