



NATIONAL WATER & SEWERAGE CORPORATION

WATER QUALITY MANAGEMENT DEPARTMENT

NEBBI AREA

Report date: 21st January-2016

Table: Water quality for Selected zones in Nebbi during the week of 11th January-2016.

Parameter	Unit	Waterworks		Monitoring points					National Standard For potable water quality (Water in Supply)
		Raw water	Final water	Water in Supply					
				Reservoir D	Nebbi Police	Nebbi Progress SS	Hill View Gardens	Aluka PSP	
CODE		N1401	N1407	N1409	N1410	N1412	N1413	N1414	
pH	8.2	7.8	8.1	8.0	8.1	8.0	8.1	5.5 – 8.5
Turbidity	NTU	18.16	1.29	1.31	1.12	1.2	1.13	0.89	≤5.00
Colour	PtCo.	263	0	0	3	0	8	0	≤15
Iron	Mg/L	0.94	0.000	0.000	0.000	0.000	0.000	0.000	≤0.300
Residue Aluminium	Mg/L	N/A	0.10	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	N/A	0.81	0.67	0.47	0.38	0.41	0.36	0.20 – 0.50
Faecal-Coliform	CFU/100 mL	764	0	0	0	0	0	0	0

N/A: Not applicable, N/R: Not Required