



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

NEBBI AREA

Report date: 19th February-2016

Table: Water quality for Selected zones in Nebbi during the week of 18th Feb, 2016.

Parameter	Unit	Monitoring points							National Standards for potable water (water in supply)
		Waterworks		Water in Supply					
		Raw water	Final water	Res A	St. Thomas Educ center	Koch Awinga S.S	Namrodh o TC	Sunris e S.S	
Codes		N1728	N1734	N1735	N1736	N1738	N1736	N1741	
pH	7.9	7.3	7.4	7.4	7.5	7.9	7.4	6.5 – 8.5
Turbidity	NTU	49.4	0.64	0.55	0.78	0.54	0.51	0.55	≤5.00
Colour	PtCo.	407	0	0	0	0	0	0	≤15
Iron	mg/L	3.18	0.01	0.01	0.01	0.01	0.01	0.01	≤0.300
Residue Aluminium	mg/L	N/A	0.15	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	NA	0.86	0.67	0.21	0.26	0.24	0.23	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	984	0	0	0	0	0	0	0

N/A: Not applicable, N/R: Not Required