



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

NEBBI AREA

Report date: 2nd March-2016

Table: Water quality for Selected zones in Nebbi during the week of 25th February, 2016.

Parameter	Unit	Monitoring points						National Standards for potable water (water in supply)
		Waterworks		Water in Supply				
		Raw water	Final water	Royal Atlas Inn	Leosim Hotel	Juba Village	Red cross Nebbi	
Codes		N1797	N1798	N1800	N1801	N1802	N1803	
pH	8.1	7.7	7.7	7.6	7.6	7.4	5.5 – 8.5
Turbidity	NTU	37	0.89	1.28	0.95	0.88	0.86	≤5.00
Colour	PtCo.	363	0	0	0	0	0	≤15
Iron	mg/L	3.1	0.00	0.00	0.00	0.00	0.00	≤0.300
Residue Aluminium	mg/L	N/A	0.00	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	NA	0.65	0.26	0.24	0.32	0.28	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	504	0	0	0	0		0

N/A: Not applicable, N/R: Not Required