



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

NEBBI AREA

Report date: 9th March 2016

Table: Water quality for Selected zones in Nebbi during the week of 3rd March, 2016.

Parameter	Unit	Monitoring points							National Standards for potable water (water in supply)
		Waterworks		Water in Supply					
		Raw water	Final Water	Reservoir B	Nebbi hospital	Nyacar a village	Thatha psp	Omyer TC	
Codes		N1872	N1878	N1881	N1882	N1883	N1884	N1885	
pH	7.9	7.6	7.7	7.8	7.7	7.8	7.8	5.5 – 8.5
Turbidity	NTU	36.20	1.50	1.44	1.48	1.38	1.30	1.28	≤5.00
Colour	PtCo.	382	7	8	8	8	0	0	≤15
Iron	mg/L	2.650	0.120	0.130	0.180	0.120	0.140	0.150	≤0.300
Residue Aluminium	mg/L	NA	0.15	NR	NR	NR	NR	NR	≤0.20
Free chlorine	mg/L	NA	0.72	0.68	0.53	0.26	0.34	0.28	0.20 – 0.50
Faecal -Coliform	CFU/ 100 mL	919	0	0	0	0	0	0	0

N/A: Not applicable, N/R: Not Required