

NEBBI AREA**Report date:** 14th December-2015**Table:** Water quality for Selected zones in Nebbi during the week 10th December 2015

Parameter	Unit	Monitoring points						National Standard For potable water quality (Water in Supply)
		Raw water	Final water	Water in Supply				
				Hill view Gardens	Nebbi police	Aluka PSP	Nebbi Progressive S.S	
Codes		N1084	N1090	N1094	N1095	N1096	N1097	
pH	8.0	7.6	7.8	7.8	7.9	8.0	5.5 – 8.5
Turbidity	NTU	41.3	0.86	1.38	0.94	1.36	1.09	≤5.00
Colour	PtCo.	366	0	0	0	0	0	≤15
Iron	Mg/L	3.15	0.06	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/L	N/A	0	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	N/A	0.75	0.26	0.46	0.38	0.30	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	416	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required