

**NEBBI AREA****Report Date:** 2<sup>nd</sup> November 2015**Table:** Water Quality for Selected Zones in Nebbi during the week starting 26<sup>th</sup> October, 2015

Parameter				Monitoring points			National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply		
				ST. Thomas Annex	Nyangam	Alyekera	
CODE		N081	N082	N083	N084	N085	
pH	....	8.03	7.61	7.85	7.47	7.01	5.5 – 8.5
Turbidity	NTU	125	0.73	1.05	1.09	0.91	≤5.00
Colour	PtCo.	1804	0	0	0	0	≤15
Iron	Mg/l	12.01	0.13	NR	NR	NR	≤0.30
Residue Aluminium	Mg/l	NA	0.10	NR	NR	NR	≤0.20
Free chlorine	Mg/L	NA	0.98	0.37	0.12	0.30	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	1613	0	0	0	0	0

NA: Not applicable, NR: Not Reported