

NEBBI AREA**Report date:** 8th December-2015**Table:** Water quality for Selected zones in Nebbi during the week starting 3rd December 2015

Parameter	Unit	Monitoring points						National Standard For potable water quality (Water in Supply)
		Raw water	Final water	Water in Supply				
				Chanan yira village	Red cross	Nebbi Town S.S	Juba village	
Codes		N1063	N1064	N1065	N1066	N1067	N1068	
pH	8.1	7.7	7.7	7.7	7.5	7.6	5.5 – 8.5
Turbidity	NTU	152	0.86	0.83	0.91	0.84	0.87	≤5.00
Colour	PtCo.	643	0	0	0	0	0	≤15
Iron	Mg/l	4.8	0	0.04	0.03	0.04	0.03	≤0.30
Residue Aluminium	Mg/l	N/A	0	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/l	N/A	0.64	0.27	0.29	0.3	0.28	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	568	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required