

NEBBI AREA

Report Date: 20th October 2015

Table: Water Quality for Selected Zones in Nebbi during the week starting 12th October 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Reservoir	Police PSP	Villa Martina	Kimatwe	
CODE		N372	N375	N376	N377	N378	N379	
pH	8.1	7.1	7.4	7.4	7.4	7.5	5.5 – 8.5
Turbidity	NTU	103	0	0	0	0	0	≤5.00
Colour	PtCo.	538	0	0	0	0	0	≤15
Iron	Mg/l	3.220	0.023	NR	NR	NR	NR	≤0.300
Residue Aluminium	Mg/l	N/A	0.20	NR	NR	NR	NR	≤0.20
Free chlorine	mg/L	NA	1.64	0.50	0.48	0.38	0.34	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	1300	0	0	0	0	0	0

NR: Not required