

NEBBI AREA**Report date:** 25th July -2015**Table:** Water quality for selected points in Nebbi during the week of 20th July 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw Water	Treat ed Water	Water in Supply					
				St.Tho mas EC	Omyer PSP	Akesi Oyera	Koch PSP	Jukia P/S	
pH	...	8.1	7.2	7.1	7.3	7.2	7.1	7.1	6.5 – 8.5
Turbidity	NTU	241.00	0.56	0.64	0.76	0.74	0.67	0.54	≤5.00
Colour	PTU	1728	0	0	5	6	1	0	≤15
Free chlorine	mg/l	N/A	1.04	0.10	0.10	0.50	0.40	0.30	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	1120	0	0	0	0	0	0	0