

NEBBI AREA**Report date:** 30th December-2015**Table:** Water quality for Selected zones in Nebbi during the week of 24th December 2015

Parameter	Unit	Monitoring points							National Standards for potable water quality Water in supply
		Water Works		Water in Supply					
		Raw water	Treated Water	Arua Hill Division	River Oli Division	Town Centre	Pajulu Subcounty	Oluko Subco unty	
CODE		AR01	AR02	AR04	AR05	AR06	AR07	AR08	
pH	...	7.6	7.2	7.4	7.2	7.4	7.1	7.2	5.5 – 8.5
Turbidity	NTU	30.1	2.52	2.87	2.88	3.44	3.14	3.28	≤5.00
Colour	PTU	205	10	10	10	10	10	10	≤15
Iron	mg/L	0.43	0.08	0.07	0.08	0.07	0.06	0.07	≤0.30
Residue Aluminium	mg/L	N/A	0.10	N/R	N/R	N/R	N/R	N/R	0.20 – 0.50
Free chlorine	mg/L	N/A	1.40	0.20	0.20	0.20	0.30	0.20	≤0.20
Faecal - Coliforms	CFU/ 100 mL	380	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required

NEBBI AREA**Report date:** 30th December-2015**Table:** Water quality for Selected zones in Nebbi during the week of 24th December 2015

Parameter	Unit	Waterworks		Monitoring points					National Standard
		Raw water	Final water	Water in Supply					For potable water quality
				Reservoir C	Reservoir D	Nebbi Police	Nebbi Progressive S.S	Classic P/S	(Water in Supply)
CODE		N684	N685	N686	N687	N688	N689	N690	
pH	8.54	8.22	8.31	8.38	8.31	8.29	8.21	5.5 – 8.5
Turbidity	NTU	38.2	0.94	1.14	1.24	1.08	1.24	1.62	≤5.00
Colour	PtCo.	203	11	12	13	10	12	15	≤15
Iron	mg/L	2.421	0.244	0.21	0.24	0.22	0.232	0.22	≤0.30
Residue Aluminium	mg/L	N/A	0.1	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/A	0.78	0.7	0.63	0.38	0.23	0.21	0.20 – 0.50
Faecal-Coliform	CFU/100 mL	940	0	0	0	0	0	0	0

N/A: Not applicable, N/R: Not Required