

NEBBI AREA**Report Date:** 7th October 2015**Table:** Water Quality for Selected Zones in Nebbi during the week of 2nd October 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Red cross	St. Thomas Educ. center	Sunrise S.S	Omyer PSP	
CODE		N058	N059	N060	N061	N062	N063	
pH	8.3	7.4	7.7	7.6	7.6	7.7	5.5 – 8.5
Turbidity	NTU	125.00	0.93	0.91	0.91	1.16	0.99	≤5.00
Colour	PtCo.	763	0	0	0	0	0	≤15
Iron	Mg/l	15.7	0.11	NR	NR	NR	NR	≤0.300
Residue Aluminium	Mg/l	N/A	0.00	NR	NR	NR	NR	≤0.20
Free chlorine	mg/L	NA	1.15	0.24	0.21	0.22	0.23	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	-	1400	0	0	0	0	0