

NEBBI AREA**Report date:** 15th September -2015**Table:** Water quality for Selected zones in Nebbi during the week of 11th September 2015

Parameter				Monitoring points			National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply		
				Reservoir B	Jukia P/S	Station Yetu	
Codes		N008	N009	N010	N012	N013	
pH	8.3	7.7	7.8	7.9	8.0	5.5 – 8.5
Turbidity	NTU	30.4	0.70	1.00	0.67	0.76	≤5.00
Colour	PtCo.	353	9	0	0	0	≤15
Iron	Mg/l	12	0.020	0.020	0.04	0.02	≤0.300
Residue Aluminium	Mg/l	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	mg/L	NA	0.93	0.77	0.44	0.51	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	1200	0	0	0	0	0

NA – Not applicable, NR – Not required