

NEBBI AREA**Report date:** 24th December-2015**Table:** Water quality for Selected zones in Nebbi during the week 17th December 2015

Parameter	Unit	Monitoring points						National Standard For potable water quality (Water in Supply)
		Raw water	Final water	Water in Supply				
				St. Thomas Educ Center	Sunrise S.S	Namrodh o P/S	Kochawinga S.S	
Codes		N1151	N1156	N1159	N1160	N1162	N1163	
pH	8.2	7.8	8.0	8.0	7.7	7.8	5.5 – 8.5
Turbidity	NTU	31.00	1.00	0.93	1.03	0.93	0.85	≤5.00
Colour	PtCo.	387	3	0	0	7	0	≤15
Iron	Mg/L	1.86	0.00	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/L	N/A	0.10	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	N/A	0.74	0.21	0.23	0.31	0.24	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	414	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required