

PAIDHA AREA**Report date:** 6th January-2015**Table:** Water quality for Selected zones in Paidha during the week of 31st December 2015

Parameter	Unit	Monitoring points						National Standard For potable water quality (Water in Supply)
		Raw water	Final water	Water in Supply				
				Jupoyik a PSP	Alengo kuma village	Aringo PSP	Rukidi Village	
Codes		N1271	N1272	N1273	N1274	N1275	N1276	
pH	6.7	7.0	7.1	7.1	6.7	6.6	5.5 – 8.5
Turbidity	NTU	7.28	1.12	1.01	0.66	0.92	0.18	≤5.00
Colour	PtCo.	36	8	9	7	11	9	≤15
Iron	Mg/l	1.91	0.23	0.21	0.18	0.14	0.19	≤0.30
Residue Aluminium	Mg/l	N/A	N/A	N/A	N/A	N/A	N/A	NA
Free chlorine	Mg/L	NA	0.48	0.22	0.33	0.31	0.26	0.20 – 0.50
Faecal -Coliform	CFU/ 100 mL	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required