

PAIDAH AREA**Report date:** 2nd November-2015**Table:** Water quality for Selected zones in Paidah during the week starting 26th October 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Arua Hill Division	River Oli Division	Town Centre	Pajulu Subcounty	Oluko subcounty	
Codes		N087	N088	N089	N090	N091	N092	N087	
pH	6.59	6.81	6.97	6.88	6.69	6.7	6.59	5.5 – 8.5
Turbidity	NTU	5.31	2.2	1.31	1.34	1.29	1.36	5.31	≤5.00
Colour	PtCo.	43	11	8	9	8	9	43	≤15
Iron	Mg/l	1.63	0.27	NR	NR	NR	NR	1.63	≤0.300
Residue Aluminium	Mg/l	NA	NA	0.14	0.16	0.14	0.11	NR	≤0.20
Free chlorine	Mg/L	NA	0.67	0.4	0.46	0.17	0.13	NR	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	0	0	0	0	0	0	0	0

NA: Not applicable, NR: Not Reported