

## PAIDHA AREA

**Report date:** 14<sup>th</sup> December-2015

**Table:** Water quality for Selected zones in Paidha during the week of 10<sup>th</sup> December 2015

Parameter	Unit	Monitoring points						National Standard For potable water quality (Water in Supply)
		Raw water	Final water	Water in Supply				
				Ovuruyi ndi PSP	Paidha PTC	Paidha market	Goli C/U	
Codes		N1084	N1090	N1100	N1101	N1102	N1103	
pH	....	8.0	7.6	6.9	6.9	7.1	7.1	5.5 – 8.5
Turbidity	NTU	41.30	0.86	0.63	0.80	0.94	1.70	≤5.00
Colour	PtCo.	366	0	0	0	0	0	≤15
Iron	Mg/L	3.15	0.06	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/L	N/A	0	N/R	N/R	N/R	N/R	NA
Free chlorine	Mg/L	N/A	0.75	0.38	0.20	0.26	0.24	0.20 – 0.50
Faecal -Coliform	CFU/100 mL	416	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required