

PAIDHA AREA**Report date:** 8th December-2015**Table:** Water quality for Selected zones in Paidha during the week starting 3rd December 2015

Parameter	Unit	Monitoring points					National Standard For potable water quality (Water in Supply)
		Raw water Jupom ocho	Final water	Water in Supply			
				Tank 2	Country cottages	Friged p/s	
Codes		N1069	N1070	N1071	N1072	N1073	
pH	6.7	7.2	7.0	6.9	6.9	5.5 – 8.5
Turbidity	NTU	12.7	7.78	0.90	0.63	1.06	≤5.00
Colour	PtCo.	72	44	0	0	0	≤15
Iron	Mg/l	2.30	1.80	0.10	0.00	0.00	≤0.30
Residue Aluminium	Mg/l	N/A	N/A	N/A	N/A	N/A	NA
Free chlorine	Mg/L	N/A	0.56	0.43	0.58	0.32	0.20 – 0.50
Faecal -Coliform	CFU/ 100 mL	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required