

PAIDHA AREA**Report date:** 24th December-2015**Table:** Water quality for Selected zones in Paidha during the week of 17th December 2015

Parameter	Unit	Monitoring points						National Standard For potable water quality (Water in Supply)
		Raw water	Final water	Water in Supply				
				Paidha Prison	Jupomo cho	Otorug ang PSP	Bible School	
Codes		N1164	N1165	N1166	N1167	N1168	N1169	
pH	6.6	6.8	6.9	6.7	6.8	6.7	5.5 – 8.5
Turbidity	NTU	7.37	4.2	2.97	2.33	1.86	2.08	≤5.00
Colour	PtCo.	34	14	9	9	4	6	≤15
Iron	Mg/L	2.30	0.30	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/L	N/A	N/A	N/A	N/R	N/R	N/R	NA
Free chlorine	Mg/L	N/A	0.44	0.22	0.26	0.26	0.28	0.20 – 0.50
Faecal -Coliform	CFU/ 100 mL	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required