

Report date: 12th March 2015

Table: Average water quality for Kampala during the period of 09th - 11th March 2015

Parameter	Monitoring points							National Standard For potable water quality
	Unit	Treated Water Water Works	Water in Supply					
			Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	7.2	7.0	7.0	7.1	7.1	7.1	6.5- 8.5
Turbidity	NTU	0.25	0.24	0.33	0.25	0.15	0.31	≤ 5.00
Colour	PTU	3	4	4	3	3	4	≤ 15
Free chlorine	mg/l	0.50	0.25	0.25	0.30	0.30	0.30	0.2-0.5
E-Coli	CFU/100 ml	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	0	0	0	0	0	0	0

Report date: 09th March 2015

Table: Average water quality for Kampala during the period of 02nd - 08th March 2015

Parameter	Monitoring points							National Standard For potable water quality
	Unit	Treated Water Water Works	Water in Supply					
			Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	7.2	7.0	7.1	7.1	7.0	7.1	6.5- 8.5
Turbidity	NTU	0.30	0.38	0.36	0.40	0.24	0.37	≤ 5.00
Colour	PTU	2	2	2	3	2	3	≤ 15
Free chlorine	mg/l	0.50	0.35	0.30	0.35	0.35	0.25	0.2-0.5
E-Coli	CFU/100 ml	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	0	0	0	0	0	0	0

Report date: 02nd March 2015

Table: Average water quality for Kampala during the period of 23rd Feb - 01st March 2015

Parameter	Monitoring points							National Standard
	Unit	Treated Water Water Works	Water in Supply					For potable water quality
			Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	7.2	7.0	7.1	7.1	7.0	7.1	6.5- 8.5
Turbidity	NTU	0.35	0.41	0.39	0.43	0.21	0.47	≤ 5.00
Colour	PTU	2	3	2	4	2	4	≤ 15
Free chlorine	mg/l	0.50	0.35	0.30	0.30	0.25	0.28	0.2-0.5
E-Coli	CFU/100 ml	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	0	0	0	0	0	0	0

Report date: 23rd February 2015

Table: Average water quality for Kampala during the period of 16th - 22rd Feb 2015

Parameter	Monitoring points							National Standard
	Unit	Treated Water Water Works	Water in Supply					For potable water quality
			Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	7.2	7.0	7.0	7.1	7.1	7.0	6.5- 8.5
Turbidity	NTU	0.28	0.27	0.30	0.29	0.13	0.34	≤ 5.00
Colour	PTU	3	5	4	3	1	5	≤ 15
Free chlorine	mg/l	0.50	0.30	0.25	0.35	0.30	0.30	0.2-0.5
E-Coli	CFU/100 ml	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	0	0	0	0	0	0	0

Report date: 26th January 2015

Table: Average water quality for Kampala during the period of 19th Jan 2015 - 25th Jan 2015

Parameter	Monitoring points								National Standard
	Unit	Raw water	Treated Water Water Works	Water in Supply					For potable water quality
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	7.0	7.1	7.0	7.1	7.0	7.0	7.1	6.5- 8.5
Turbidity	NTU	16	0.36	0.28	0.33	0.30	0.20	0.40	≤5.00
Colour	PTU	192	4	3	5	4	2	5	≤15
Free chlorine	mg/l	NA	1.26	0.25	0.35	0.45	0.45	0.20	0.20-0.50
E-Coli	CFU/100 ml	26	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	40	0	0	0	0	0	0	0

NA: Not applicable

Report date: 19th January 2015

Table: Average water quality for Kampala during the period of 12th Jan 2015 - 18th Jan 2015

Parameter	Monitoring points								National Standard
	Unit	Raw water	Treated Water Water Works	Water in Supply					For potable water quality
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	7.1	6.8	6.8	6.7	6.7	6.8	6.9	6.5- 8.5
Turbidity	NTU	15	0.43	0.43	0.40	0.39	0.13	0.40	≤ 5.00
Colour	PTU	181	3	6	4	3	2	5	≤ 15
Free chlorine	mg/l	NA	1.35	0.30	0.45	0.50	0.60	0.25	0.20-0.50
E-Coli	CFU/100 ml	24	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	38	0	0	0	0	0	0	0

NA: Not applicable

Report date: 12th January 2015

Table: Average water quality for Kampala during the period of 5th - 11st Jan 2015

Parameter	Monitoring points								National Standard
	Unit	Raw water	Treated Water Water Works	Water in Supply					For potable water quality
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	7.3	7.1	7.2	7.2	7.1	7.2	7.2	6.5- 8.5
Turbidity	NTU	17	0.26	0.41	0.32	0.30	0.29	0.33	≤ 5.00
Colour	PTU	195	3	2	6	5	1	4	≤ 15
Free chlorine	mg/l	NA	1.36	0.30	0.50	0.40	0.50	0.25	0.20-0.50
E-Coli	CFU/100 ml	24	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	44	0	0	0	0	0	0	0

NA: Not applicable

Report date: 05th January 2015

Table: Average water quality for Kampala during the period of 29th Dec 2014 - 04th Jan 2015

Parameter	Monitoring points								National Standard
	Unit	Raw water	Treated Water Water Works	Water in Supply					For potable water quality
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	7.3	6.9	6.9	7.0	6.8	7.0	7.0	6.5- 8.5
Turbidity	NTU	16.5	0.12	0.20	0.22	0.38	0.17	0.28	≤ 5.00
Colour	PTU	187	0	3	3	4	1	2	≤15
Free chlorine	mg/l	NA	1.46	0.33	0.40	0.50	0.55	0.30	0.20-0.50
E-Coli	CFU/100 ml	29	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	42	0	0	0	0	0	0	0

NA: Not applicable