

SIRONKO AREA**Report date:** 9th September -2015**Table:** Water quality for Selected zones in Sironko during the week of 3rd September 2015

Parameter				Monitoring points		National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply	
				Northern Zone	Southern zone	
Codes		N001	N002	N003	N004	
pH	7.27	7.1	7.1	7.1	5.5 – 8.5
Turbidity	NTU	58.00	0.56	0.62	0.49	≤5.00
Colour	PtCo.	450	7	4	4	≤15
Iron	Mg/l	0.560	0.120	0.090	0.100	≤0.300
Residue Aluminium	Mg/l	-	0.10	0.09	0.12	≤0.20
Free chlorine	mg/L	N/A	0.80	0.40	0.4	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	0	0	0	0	0