



**NATIONAL WATER & SEWERAGE CORPORATION  
WATER QUALITY MANAGEMENT DEPARTMENT**

**SOROTI**

**Report date:** 2<sup>nd</sup> March 2016

**Table:** Water quality for Soroti during the week of 25<sup>th</sup> February 2016

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water	Water in Supply				
				Northern Zone	Western zone	Southern zone	Central zone	
Code		N149	N150	N151	N152	N154	N155	
pH	...	7.5	7.4	7.5	7.5	7.4	7.5	6.5 – 8.5
Turbidity	NTU	1.7	0.62	0.55	0.69	0.67	0.51	≤5.00
Colour	PTU	ND	ND	ND	ND	ND	ND	≤15
Iron	mg/l	0.08	0.02	0.01	0.02	0.04	0.04	0.30
Residual Al	mg/l	N/A	0.00	0.00	0.00	0.01	0.01	0.20
Free chlorine	mg/l	N/A	1.1	0.25	0.21	0.22	0.20	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	22	0	0	0	0	0	0

NA: Not applicable