



NATIONAL WATER & SEWERAGE CORPORATION

WATER QUALITY MANAGEMENT DEPARTMENT

TORORO AREA

Report date: 3rd November, 2016

Table: Water quality for selected zones in Tororo during the week of 30th October, 2016

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water	Water in Supply				
				Tororo North	Tororo South	Malaba Territory	Tororo West	
Code		N2378	N2379	N2380	N2381	N2382	N2383	
pH	...	7.5	7.4	7.3	7.3	7.4	7.3	6.5 – 8.5
Turbidity	NTU	162.00	0.76	0.63	0.74	0.83	0.27	≤5.00
Colour	PTU	1500	0	4	0	3	3	≤15
Iron	mg/l	0.340	0.040	0.000	0.030	0.020	0.040	0.300
Free Chlorine	mg/l	N/A	1.00	0.32	0.26	0.24	0.40	0.20 – 0.50
Faecal -Coliforms	CFU/ 100 ml	1300	0	0	0	0	0	0

NA: Not applicable