



**NATIONAL WATER & SEWERAGE CORPORATION  
WATER QUALITY MANAGEMENT DEPARTMENT**

**TORORO AREA**

**Report date:** 10<sup>th</sup> June 2016

**Table:** Average water quality for selected zones in **Tororo** during the week of 2<sup>nd</sup> June 2016

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water	Water in Supply				
				Tororo North	Tororo West	Tororo South	Malaba Territory	
Code		N296	N297	N298	N299	N300	N301	
pH	...	7.2	6.9	7.0	6.9	7.0	7.0	5.5 – 8.5
Turbidity	NTU	420	1.46	0.49	0.51	0.40	0.30	≤5.00
Colour	PTU	4652	12	5	12	8	3	≤15
Iron	mg/l	3.50	0.09	0.07	0.08	0.04	0.08	≤0.300
Residual Al	mg/l	N/A	0.08	0.07	0.06	0.09	0.04	≤0.20
Free Chlorine	mg/l	N/A	1.33	0.20	0.25	0.4	0.30	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	2800	0	0	0	0	0	0

NA: Not applicable