



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

TORORO AREA

Report date: 10th Oct 2016

Table: Average water quality for **Tororo** during the week ending 6th Oct 2016

Water: Average water quality for Tororo during the week ending 3 rd Oct 2016								
Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water	Water in Supply				
				Toror o North	Toror o South	Malab a Territo ry	Tororo West	
Code		N2244	N2245	N2246	N2244	N2245	N2246	
pH	...	7.5	7.0 7.0	7.0	7.0	7.0	7.0	6.5 – 8.5
Turbidity	NTU	139	0.40	0.37	0.31	0.28	0.27	≤5.00
Colour	PTU	1350	4	1	0	0	3	≤15
Iron	mg/l	0.42	0.0	0.0	0.0	0.01	0.00	0.30
Residual Al	mg/l	N/A	0.00	0.00	0.00	0.00	0.00	0.20
Free Chlorine	mg/l	N/A	1.2	0.4	0.3	0.3	0.4	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	2200	0	0	0	0	0	0

NA: Not applicable