



NATIONAL WATER & SEWERAGE CORPORATION

WATER QUALITY MANAGEMENT DEPARTMENT

TORORO AREA

Report date: 25th January 2015

Table: Average water quality for Tororo during the week starting 18th January 2016

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water	Water in Supply				
				Tororo North	Tororo West	Tororo South	Malaba Territory	
Code		N114	N115	N116	N117	N118	N119	
Ph	...	7.1	6.9	7.0	7.0	6.9	7.1	6.5 – 8.5
Turbidity	NTU	240	<5.00	<5.00	<5.00	<5.00	<5.00	≤5.00
Colour	PTU	1500	0	0	0	0	0	≤15
Iron	Mg/L	0.88	0.020	0.050	0.020	0.010	0.010	0.300
Residual Al	Mg/L	N/A	0.00	N/R	N/R	N/R	N/R	0.20
Free Chlorine	Mg/L	N/A	1.1	0.40	0.28	0.25	0.22	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	4700	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required