



**NATIONAL WATER & SEWERAGE CORPORATION  
WATER QUALITY MANAGEMENT DEPARTMENT**

**TORORO AREA**

**Report date:** 2<sup>nd</sup> March 2016

**Table:** Average water quality for Tororo during the week of 25th February 2016

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water	Water in Supply				
				Tororo North	Tororo West	Tororo South	Malaba Territory	
Code		N136	N137	N138	N139	N140	N141	
Ph	...	7.4	7.3	7.3	7.2	7.3	7.4	6.5 – 8.5
Turbidity	NTU	82	<5.00	<5.00	<5.00	<5.00	<5.00	≤5.00
Colour	PTU	494	0	0	0	0	0	≤15
Iron	mg/l	0.33	0.02	0.04	0.05	0.06	0.04	0.30
Residual Al	mg/l	N/A	0.00	0.00	0.00	0.00	0.00	0.20
Free Chlorine	mg/l	N/A	1.4	0.3	0.2	0.2	0.2	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	3500	0	0	0	0	0	0

NA: Not applicable