

**TORORO AREA****Report date:** 3<sup>rd</sup> July -2015**Table:** Water quality for selected zones in Tororo during the week of 1<sup>st</sup> July 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water	Water in Supply				
				Tororo North	Tororo West	Tororo South	Malaba Territory	
pH	---	6.76	6.67	6.63	6.57	6.68	6.78	6.5 – 8.5
Turbidity	NTU	29.6	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PTU	1992	8	6	3	7	6	≤15
Free chlorine	mg/l	N/A	1.17	0.40	0.40	0.30	0.10	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	4500	0	0	0	0	0	0