

TORORO AREA**Report date:** 14th December -2015**Table:** Water quality for Selected zones in **Tororo** during the week of 10th December 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Tororo North	Tororo West	Tororo South	Malaba Territory	
Codes		N084	N085	N086	N087	N088	N089	
pH	7.1	7.1	7.0	6.9	6.8	6.8	5.5 – 8.5
Turbidity	NTU	360	<5.00	<5.00	<5.00	<5.00	<5.00	≤5.00
Colour	PtCo.	3912	0	0	0	0	0	≤15
Iron	Mg/L	0.8	0.04	0.07	0.03	0.04	0.02	≤0.30
Residue Aluminium	Mg/L	N/A	0.00	0.00	0.00	0.00	0.00	≤0.20
Free chlorine	Mg/L	N/A	1.06	0.40	0.30	0.30	0.20	0.20 – 0.50
Faecal – Coliform	CFU/ 100 mL	6000	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required