

TORORO AREA**Report date:** 25th November**Table:** Average water quality for Tororo during the week of 19th November 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water	Water in Supply				
				Tororo North	Tororo West	Tororo South	Malaba Territory	
Code		N066	N067	N068	N069	N070	N071	
pH	...	6.8	6.7	7.1	7.3	7.2	7.2	6.5 – 8.5
Turbidity	NTU	313	<5.00	<5.00	<5.00	<5.00	<5.00	≤5.00
Colour	PTU	4333	5	0	0	4	0	≤15
Iron	mg/l	0.6	0.02	0.03	0.00	0.04	0.01	0.30
Residual Al	mg/l	N/A	0.00	0.00	0.00	0.00	0.00	0.20
Free chlorine	mg/l	N/A	1.20	0.4	0.15	0.2	0.3	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	7300	0	0	0	0	0	0

N/A: Not applicable