

TORORO AREA**Report date:** 30th November**Table:** Average water quality for Tororo during the week of 26th November 2015

Parameter	Monitoring points							National Standard For potable water quality
	Unit	Raw water	Treated Water	Water in Supply				
				Tororo North	Tororo West	Tororo South	Malaba Territory	
Code		N072	N073	N074	N075	N076	N077	
pH	NA	7.1	7.0	6.9	7.0	7.0	7.1	6.5 – 8.5
Turbidity	NTU	164	<5	<5	<5	<5	<5	≤5.00
Colour	PTU	1489	0	0	0	11	0	≤15
Iron	mg/l	0.4	0.03	0.02	0.03	0.09	0.07	0.30
Residual Al	mg/l	N/A	0	0	0	0	0	0.20
Free chlorine	mg/l	N/A	1.21	0.3	0.20	0.2	0.3	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	4200	0	0	0	0	0	0

NA: Not applicable