

TORORO AREA**Report date:** 2nd November 2015**Table:** Water quality for Selected points in Tororo during the week starting 26th October 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply				
				Tororo North	Tororo West	Tororo South	Malaba Territory	
Codes		N042	N043	N044	N045	N046	N047	
pH	6.9	6.6	6.5	6.6	6.5	6.5	5.5 – 8.5
Turbidity	NTU	312	<5	<5	<5	<5	<5	≤5.00
Colour	PtCo.	3370	7	0	0	0	10	≤15
Iron	Mg/l	0.9	0.06	0.02	0.05	0.07	0.02	≤0.30
Residue Aluminium	Mg/l	NA	0	0	0	0	0	≤0.20
Free chlorine	Mg/L	NA	1.23	0.5	0.2	0.3	0.5	0.20 – 0.50
Faecal – Coliform	CFU/ 100 mL	6100	0	0	0	0	0	0

NA: Not applicable