

**TORORO AREA****Report date:** 16<sup>th</sup> November**Table:** Average water quality for Tororo during the week of 12<sup>th</sup> November 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water	Water in Supply				
				Tororo North	Tororo West	Tororo South	Malaba Territory	
Code		N060	N061	N062	N063	N064	N065	
pH	...	7.0	7	7.2	7.2	7.2	7.3	6.5 – 8.5
Turbidity	NTU	468	<5	<5	<5	<5	<5	≤5.00
Colour	PTU	4333	7	9	10	11	0	≤15
Iron	mg/l	0.7	0.03	0.05	0.08	0.05	0.04	0.30
Residual Al	mg/l	N/A	0	0	0	0	0	0.20
Free chlorine	mg/l	N/A	1.15	0.3	0.25	0.3	0.2	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	0400	0	0	0	0	0	0

NA: Not applicable