

TORORO AREA**Report date:** 29th June -2015**Table:** Water quality for different zones in Tororo during the week of 22nd June 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water Water Works	Water in Supply				
				Tororo North	Tororo West	Tororo South	Malaba Territory	
pH	...	7.17	6.96	7.09	6.99	6.97	7.01	6.5 – 8.5
Turbidity	NTU	320	0	0	0	0	0	≤5.00
Colour	PTU	3593	10	8	7	9	8	≤15
Free chlorine	mg/l	N/A	1.34	0.30	0.30	0.4	0.2	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	4500	0	0	0	0	0	0