

## TORORO AREA

**Report Date:** 20<sup>th</sup> October 2015

**Table:** Water Quality for Selected Zones in Tororo during the week starting 12<sup>th</sup> October 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Tororo North	Tororo West	Tororo South	Malaba Territory	
CODE		N020	N021	N023	N024	N025	N26	
pH	...	73	6.5	6.7	6.8	6.9	6.9	5.5 – 8.5
Turbidity	NTU	110.00	2.00	0.00	0.00	3.10	1.02	≤5.00
Colour	PtCo.	979	12	0	2	12	8	≤15
Aluminium resd.	mg/L	NA	0.14	NR	NR	NR	NR	0.20
Free chlorine	mg/L	NA	1.2	0.4	0.4	0.5	0.20	0.20 – 0.50
Feacal coliforms	CFU/10 0 mL	NT	6300	0	0	0	0	0

NR: Not required