

TORORO AREA**Report date:** 22nd June -2015**Table:** Average water quality for different zones in Tororo during the week of 15th June 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water Water Works	Water in Supply				
				Tororo North	Tororo West	Tororo South	Malaba Territory	
pH	...	7.05	6.96	6.93	6.97	6.91	6.98	6.5 – 8.5
Turbidity	NTU	371	1	0	0	0	0	≤5.00
Colour	PTU	4826	7	9	6	7	4	≤15
Free chlorine	mg/l	N/A	1.14	0.4	0.3	0.5	0.2	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	8500	0	0	0	0	0	0