

TORORO AREA

Report date: 08 -06-2015

Table: Average water quality for TORORO AREA during the period of 1st June - 7th June 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water Water Works	Water in Supply				
				Tororo North	Tororo West	Tororo South	Malaba Territory	
pH	...	7.5	7.3	7.3	7.5	7.3	7.4	6.5 – 8.5
Turbidity	NTU	410	0	0	0	0	0	≤5.00
Colour	PTU	5450	0	11	11	13	12	≤15
Free chlorine	mg/l	N/A	1.0	0.25	0.20	0.30	0.15	0.20 – 0.50
Faecal -Coliforms	CFU/ 100 ml	7900	0	0	0	0	0	0

