

TORORO AREA**Report date:** 24th July -2015**Table:** Water quality for selected zones in Tororo during the week of 20th July 2015

| Parameter | Monitoring points | | | | | | | National Standard For potable water quality (Water in Supply) |
|--------------------|-------------------|-----------|---------------|-----------------|-------------|--------------|------------------|---|
| | Unit | Raw water | Treated Water | Water in Supply | | | | |
| | | | | Tororo North | Tororo West | Tororo South | Malaba Territory | |
| pH | ... | 7.03 | 6.84 | 7.1 | 7.0 | 7.1 | 7.2 | 6.5 – 8.5 |
| Turbidity | NTU | 760.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | ≤5.00 |
| Colour | PTU | 8766 | 3 | 0 | 3 | 2 | 0 | ≤15 |
| Free chlorine | mg/l | N/A | 1.22 | 0.40 | 0.40 | 0.40 | 0.20 | 0.20 – 0.50 |
| Faecal - Coliforms | CFU/ 100 ml | 1000 | 0 | 0 | 0 | 0 | 0 | 0 |